

EC Declaration of Conformity

| |
|---------------------------------------|
| American Power Conversion (APC) |
| 132 Fairgrounds Road |
| West Kingston, Rhode Island 02892 USA |

and our authorized representative established within the community,

| |
|---------------------------------|
| American Power Conversion (APC) |
| Ballybrit Business Park |
| Galway, Ireland |

declare under our sole responsibility that the products

| | |
|---------------------------|---------------------------------|
| Type | Rack Power Distribution Units |
| Trademark | APC by Schneider Electric |
| Models | AP86xxxxx, AP88xxxxx, AP89xxxxx |
| Year of CE marking | 09 |

through their design and construction meet the requirements of the European Directives and applicable standards listed below when installed and used in accordance with the instructions contained in the product documentation.

| |
|------------------------|
| Directives |
| Low Voltage 2006/95/EC |
| EMC 2004/108/EC |

| |
|--|
| Standards |
| EN 60950-1:2006/A11:2009 - ITE – Safety – Part 1: General Requirements |
| EN 55022:2006/A1:2007 - ITE – Radio disturbance characteristics |
| EN 55024:1998/A1:2001/A2:2003 - ITE – Immunity Characteristics |
| Additionally for models with rated current ≤ 16 amps the following standards apply: |
| EN 61000-3-2:2006/A1:2009/A2:2009 - EMC -- Part 3-2: Limits - Limits for harmonic current emissions (equipment input current ≤ 16 A per phase) |
| EN 61000-3-3:2008 - EMC -- Part 3-3: Limits - Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated current ≤ 16 A per phase |

| | |
|-------------------|---|
| Date: | 01 August 2011 |
| Signature: |  |
| Name: | Richard Zeh |
| Title: | Staff Compliance Engineer |