
+

THIS COPY IS PROVIDED ON A RESTRICTED BASIS AND IS NOT TO BE USED IN ANY WAY DETRIMENTAL TO THE INTERESTS OF PANDUIT CORP.





PANDUIT PART NO.	WE I GHT
PIIOKT3004Y	9.95 LB/ea 4522.73g/ea
P110KT3005Y	9.95 LB/ea 4522.73g/ea


NOTES:

- I. SEE CURRENT CATALOG FOR ADDITIONAL PART NUMBER SUFFIXES TO INDICATE PACKAGE QUANTITY.
- 2. 300 PAIR 110 TOWER ASSEMBLY IS DESIGNED FOR WALL MOUNT APPLICATIONS, PROVIDES VERTICAL CABLE MANAGEMENT, AND SUPPLIED JUMPER TROUGHS PROVIDE HORIZONTAL CABLE MANAGEMENT.
- 3. ASSEMBLY COMES WITH FASTENER
 KIT WHICH INCLUDES THE FOLLOWING:
 (2) #12 X 1/2" SHEET METAL SCREWS,
 (2) #12 LOCK WASHERS, (1) 1/4-20 X
 3/4 MACHINE SCREW, (1) 1/4-20 HEX
 NUT, (2) 1/4" LOCK WASHERS.
- 4. ALSÓ INCLUDED WITH TOWER IS A SCREW KIT USED TO MOUNT THE JUMPER TROUGHS AND BASES.



- 6. SEE CHART FOR NUMBER OF CONNECTING BLOCKS INCLUDED FOR EACH PART NUMBER.
- 7. DIMENSIONS IN PARENTHESES ARE IN METRIC.

	CONNECTING BLOCKS	
PART NUMBER	4 PAIR (PIIOCB4-+Y)	5 PAIR (PIIOCB5-+Y)
PIIOKT3004Y	60	12
P110KT3005Y	12	60



THIS COPY IS PROVIDED ON A RESTRICTED BASIS AND IS NOT TO BE USED IN ANY WAY DETRIMENTAL TO THE INTERESTS OF PANDUIT CORP. **←** 6.08 → **←** 7.00 → [154.4] [177.8] 3.56 [90.5] CABLE TIE 110 -MOUNTS (4) BASES (3) - WALL MOUNTS (4) 2.00 DIA JUMPER -12.60 THORUGH (3) [50.8] [320.0] CABLE ACCESS HOLE SIDE VIEW BACK VIEW HORIZONTAL CABLE MANAGER .25 3.75 [6.4] [95.2]8.63 [219.2] - 7.18 — REF. [182.4] SIZE REF. DRAWING FILENAME M02479NB_DC341_00B.PRT PAN-PUNCH CATEGORY 5e TOWER SYSTEM - 300 PAIR /b\ CUSTOMER DRAWING CORP PRODUCT SPEC/ PKG SPEC TINLEY PARK, ILL 60477 ALL DIMENSIONS ARE GIVEN IN INCHES, UNLESS OTHERWISE SPECIFIED, ASSY METHOD/ TEST METHOD DIMENSIONAL TOLERANCES ARE: (.XXX) ±.010(.3) SCALE NONE (.XX) ±.03(.8) ANGLES ± PART NO. REVIEW DRAWING NUMBERS NER SEE TABLE 1 3-24-06 MAT'L BJN EJH SEE SHEET I FOR REVISIONS 02479-341 KMCL 5-21-07 DRAWING NO. 02479-341 SEE NOTES DATE BY CHK DESCRIPTION CUST SUP ECN -R SH 2 OF 2