

GE Magnetic Contacts

1078 Series

1" Diameter Steel Door



Gap Distance		Closed Loop	SPDT
In Steel	In Wood		
Up to 1/2"	1"	1078	1076
Up to 1"	2"	1078W	1076W
<i>Up to 3/8"</i>	3/4"		1076D DPDT (no Canadian listing)

Color	Natural, Mahogany, Grey
Ouantity	10



100% **TESTED**






1078 Series

1" Diameter Steel Door with Wire Leads

Installation Instructions

- 1. Drill appropriate diameter and depth holes for contact and magnet for contact $(1"x 1^1/8" \text{ for contact and } 1"x 1^1/2" \text{ for magnet}).$
- 2. Connect contact leads to security system loop and test for continuity.
- 3. Lightly coat the contact and magnet with RTV mounting compound (part number 1905) and insert into respective holes.



UL Specifications

Part	Loop	Electrical	Gap Distance	
Number	Туре	Configuration	In Steel	In Wood
1076	Open or Closed	SPDT	Up to 1/2"	1"
1076W	Open or Closed	SPDT	Up to 1"	2"
1076D (no Canadian listing)	Open or Closed	DPDT	Up to 3/8"	3/4"
1078	Closed	N/O	Up to 1/2"	1"
1078W	Closed	N/O	Up to 1"	2"

** FORM A (1078, 1078W) FORM C (1076, 1076W)

Voltage: 100V AC/DC max

Current: 0.5A max

Power: 7.5W max Power: 3.0W max

WARNING: Each electrical rating is an individual maximum and cannot be exceeded!

C-UL Specifications

All Contacts: 30V DC, 50 mA max

Gap Specifications:*

See UL Gap Specifications



GE Interlogix

www.GE-Interlogix.com

12345 SW Leveton Drive Tualatin, OR 97062 Phone: 503-692-4052 USA & Canada: 800-547-2556 Technical Service: 800-648-7424 Faxback: 800-483-2495 2266 Second Street North North St. Paul, MN 55109 Phone: 651-777-2690 USA & Canada: 800-777-5484 Technical Service: 800-777-2624

1040683 Rev A 01/03 Made in Taiwan

^{*} Gap specifications are nominal and may vary ± 20%. Gap specifications are for switch to make.

Break distance is approximately 1.1 to 1.5 times make.

** European Union Specifications: 48V AC/DC max., 0.5 Amp