

**Overview**

- These multi-agency approved multi-output power supply/chargers convert a 115VAC/60Hz input to sixteen (16) Class 2 rated 12VDC or 24VDC power limited outputs.

AL300ULXPD16

- Fuses are rated @ 3.5 amp/250V
- Grey enclosure.

AL300ULXPD16R

- Red enclosure

AL300ULXPD16CB

- PTCs are rated @ 2.5 amp.
- Grey enclosure.

AL300ULXPD16CBR

- Red enclosure

Specifications

- | | |
|---|--|
| <ul style="list-style-type: none">• 12VDC or 24VDC selectable outputs.• 2.5 amp supply current.• Class 2 Rated power limited outputs.• Sixteen (16) protected outputs.• Input 115VAC / 60Hz, 1.45 amp.• Input fuse rated @ 3.5 amp/250V.• Filtered and electronically regulated outputs.• Short circuit and thermal overload protection.• Built-in charger for sealed lead acid or gel type batteries.• Maximum charge current .7 amp. | <ul style="list-style-type: none">• Automatic switch over to stand-by battery when AC fails (zero voltage drop).• AC fail supervision (form “C” contacts).• Low battery supervision (form “C” contacts).• Battery presence supervision (form “C” contacts).• AC input and DC output LED indicators.• Enclosure:<ul style="list-style-type: none">- Combination knockouts are 1/2” and 3/4”- Accommodates up to two (2) 12VDC/12AH batteries. |
|---|--|

Agency Approvals

- | | |
|---------|---|
| UL 294 | UL Listed for Access Control System Units. |
| UL 603 | UL Listed Standard for Power Supplies for Use with Burglar-Alarm Systems. |
| UL 1069 | UL Listed Hospital Signaling and Nurse Call Equipment. |
| UL 1481 | UL Listed Standard for Safety for Fire Protective Signaling Systems. |



- | |
|---|
| CUL Listed - CSA Standard C22.2 No.205-M1983, Signal Equipment. |
|---|

Enclosure Dimensions

15"H x 12"W x 4.5"D

