# Product Specifications






760070367 | 2071E OR 4/23 R3000

GigaSPEED XL® 2071E ETL Verified Category 6 U/UTP Cable, plenum, orange jacket, 4 pair count, 3000 ft (914 m) length, reel

### **Cross Section Drawing**



### **Construction Materials**

Jacket Material PVC

Conductor Material Bare copper
Insulation Material FEP | Polyolefin

Separator Material Flame retardant polyolefin

#### **Dimensions**

Cable Length 914 m | 3000 ft

Cable Length Tolerance ±5%

Cable Weight 29.00 lb/kft

Diameter Over Jacket 5.740 mm | 0.226 in Jacket Thickness 0.559 mm | 0.022 in

## **Electrical Specifications**

ANSI/TIA Category 6

dc Resistance Unbalance, maximum 5 %

dc Resistance, maximum 7.61 ohms/100 m

Mutual Capacitance 5.6 nF/100 m @ 1 kHz

Nominal Velocity of Propagation (NVP) 71 % Operating Frequency, maximum 300 MHz

# **Product Specifications**



760070367 | 2071E OR 4/23 R3000

Operating Voltage, maximum

Transmission Standards

ANSI/TIA-568-C.2 | CENELEC EN 50288-6-1 | ISO/IEC 11801 Class E

Dielectric Strength, minimum 1500 Vac | 2500 Vdc

### **Environmental Specifications**

Environmental Space Plenum Flame Test Method CMP

Installation Temperature  $0 \, ^{\circ}\text{C} \text{ to } +60 \, ^{\circ}\text{C} \text{ (+32 } ^{\circ}\text{F to } +140 \, ^{\circ}\text{F)}$ Operating Temperature  $-20 \, ^{\circ}\text{C} \text{ to } +60 \, ^{\circ}\text{C} \text{ (-4 } ^{\circ}\text{F to } +140 \, ^{\circ}\text{F)}$ 

80 V

Smoke Test Method CMP

UL Temperature Rating 75 °C | 167 °F

### **General Specifications**

Cable Type U/UTP (unshielded)

Pairs, quantity 4

Cable Component Type Horizontal Packaging Type Reel

Brand GigaSPEED XL® | SYSTIMAX®

Jacket ColorOrangeProduct Number2071EConductor Gauge, singles23 AWGConductor Type, singlesSolidConductors, quantity8Separator TypeBisector

### **Mechanical Specifications**

Pulling Tension, maximum 11 kg | 25 lb

# **Regulatory Compliance/Certifications**

**Agency**RoHS 2011/65/EU

Classification
Compliant

ISO 9001:2008 Designed, manufactured and/or distributed under this quality management system

