Step 6 – While holding the access point in position, use the two spring loaded captured thumb screws to secure the access point to the mounting plate by screwing into the threaded holes located in the keyhole slots on the bottom of the access point (*Ref. Figure 6*).




Figure 6

Step 7 – Reattach the door to the backbox in the ceiling.

Step 8 – Plug the equipment cord into the surface mount box. If a surface mount box was not used, plug the data cable directly into the access point. Close and lock the access door. The installation is now completed.



MODEL 1046-EX3900

Installation Instructions

**** **WARNING** ****

Please thoroughly read the product warning below before installation to provide for a safe work environment.

- 1. Ceiling mounted products should be installed in accordance with National Electric Code paragraphs 300.10 (Electrical Continuity of Metal Raceways and Enclosures) and 300.11 (Securing and Supporting). Independent support wires or other means must be used for the installation of this product in the ceiling. Acoustical, suspended, false, drop and concealed spline ceiling grid work is not designed to support the weight of this product. Oberon's ceiling mounted products have four support wire tabs on the back box. These tabs shall be used for supporting the product with independent support wires, wire rope, threaded rod, or other secure support means of adequate gauge and fire resistance.
- 2. When closing the enclosure access door, be sure that the cam lock is completely engaged to prevent the access door from accidentally swinging open.
- 3. When opening the enclosure door, be sure to support the door to prevent the door from accidentally falling open.
- 4. This enclosure has a maximum operating ambient of 55° C (131° F), the temperature within the enclosure may not exceed this temperature, depending on power dissipation within enclosure.
- 5. A minimum air clearance of 1" between the housing of the access point and the enclosure side walls must be maintained for the safe operation of the equipment.
- 6. This product is intended to be installed by trained personnel.
- 7. Only Listed ITE products shall be installed within the enclosure.
- 8. This product is to be repaired by personnel trained by the manufacturer or returned to the manufacturer for repair or replacement.
- 9. Maximum weight to be installed in the unit is 25 lbs.
- 10. All knockouts, openings, and holes shall be sealed with a plug constructed of metal, or a non-metal material that complies with UL 2043 or UL 1479.
- 11. All unused mounting holes should be sealed with tape or other material that complies with UL 1479.
- 12. AC Power is not to be used inside the enclosure.
- 13. See OSHPD approved installation drawing where applicable

Installation Instructions

Model Number 1046-EX3900

Assembly Components:

- Ceiling enclosure Model 1046-EX3900 assembly 1 each
- 1" Trade size conduit connectors 1 each
- Firestop Grommet 1 each
- #8 32 screw 4 each
- -1/4" standoffs 4 each
- Support wire 4 each
- Installation Instructions 1 each
- Keys for access door lock 2 each

If any of these items are missing, contact your Oberon representative.

For ease of access point installation, and to prevent damage to the door hinge, it is recommended that you remove the door from the enclosure. To remove, open the door to a 90° angle and aligning the tabs of the door mount to the slots in the back box hinge opening and slide the door forward (Ref. Figure 1).

Step 1 – Place the *ceiling enclosure back box* assembly on the work surface. Determine which knockout is to be used to bring in the Ethernet cable and remove the knockout. (Ref. Figure 2). Install the conduit fitting from the inside of the enclosure. Insert the conduit fitting through the hole with the nut installed from the outside of the enclosure (ref. Figure 2).

NOTE: A surface mount box (or biscuit jack) and equipment cord can be conveniently mounted inside the Model 1046. (Non-plenum rated cables can be used inside a plenum rated enclosure). Use an adhesive backed surface mount box. Consider bend radius of horizontal cable and equipment cord when attaching the surface mount box.




Figure 1





Figure 2


Step 2 - Remove the ceiling tile and replace it with the enclosure backbox.

Step 3 - Use minimum 12-gauge support wire (included) to support the access point enclosure independently of the ceiling grid. Attach one end of the wire to the support wire tabs located along the edge of the back box and the other end to a permanent supporting structure within the ceiling such as a ceiling joist (Ref. Figure 3).

IMPORTANT - This is an important safety feature that could prevent human injury or damage to the access point should the unit become dislodged from the ceiling.

Step 4 - Run the data cable through the conduit connectors located on sides of the access point enclosure. Pull the data cable through the conduit connector far enough to allow attachment to the access point (8" - 10"). Snap the firestop grommet on to the cable and slide it inside the conduit connector (Ref. Figure 4).





Attach to a permanent

Firestop Grommet

Figure 4

Step 5 - To install the Extreme AP, lift the EX3935 access point into the opening in the door. With one hand, press the access point to the bottom surface of the mounting plate (Ref. Figure 5).

Figure 5

Page 2 Page 3